

METHODICAL TUNING OF PROPORTIONAL PLUS INTEGRAL CONTROLLERS FOR CASCADE CONTROL OF SEPARATELY EXCITED DC MOTORS

Ibrahim Al-Abbas

Department of Mechatronics Engineering,
Faculty of Engineering Technology, Al-Balqa Applied University, Amman, Jordan

Received 2012-06-27, Revised 2012-09-07; Accepted 2012-09-12

ABSTRACT

The cascade control of DC motors by PI controllers was extensively used in industry. Approximation rules based on plotting the output of the system or on computer simulation were used to determine the parameters of these controllers. This study was done to develop mathematical expressions to calculate the parameters of these controllers. Output time functions of the system and their derivatives were used to obtain mathematical relationships relating directly the motor parameters and the controller parameters. These relationships were used in tuning process of the cascade system. The dynamic performances of the system were examined in single loop form and in closed loop form for a step change in control variable (the input voltage) as well as for step change in disturbance (mechanical load). The performances of current closed loop system and the speed closed loop were acceptable. The steady state error was zero and the maximum overshoot was less than 20%. The developed relationships can be used in design and analysis of cascade DC drive systems and cascade AC drive systems.

Keywords: Cascade Control, DC Motor, Ziegler Nichols, PI Control

1. INTRODUCTION

Cascade control of Separately Excited Direct Current (SEDC) motors can improve system performances over single-loop control, the control system has inner (current) loop and outer (speed) loop, where Proportional Plus Integral (PI) controller is implemented in each loop to provide fast response and zero steady state error. Different methods are used to select the gain and the time constant of PI controllers, these methods can be classified into three groups: The first one is Ziegler Nichols tuning rules used the plotted output time response curves (Sing and Pandey, 2012). Lee (2004) used the calculated gain margin and phase margin of the open loop system, it is known that gain and phase margins have served as important measures of robustness. The phase margin is related to the damping of the system from classical control theories and therefore also serves as a performance measurement. Their solutions are normally obtained numerically or graphically using bode plots. Moleykutty (2008) proposed a second method based on trial and error tuning of the controller from the simulated cascade

SEDC motor. The third method is the transfer function approach (Neenu and Poongodi, 2009) where the order of the open loop system is reduced to a second order with known parameters. To implement these methods some specifications should be measured to design the controller, therefore they can be considered as indirect tuning methods.

In this study direct tuning methods for current controller and for speed controller are suggested, where the parameters of these controllers are calculated using obtained mathematical expressions without any plotting or simulations. For current (torque) loop using the time response output and its first and second derivatives mathematical expressions were obtained to determine the proportional gain and the time constant of PI controller from the parameters of the DC motor. For speed loop the characteristic equation of the closed loop system is used to relate the motor parameters and controller parameters. The cascade system is simulated using calculated parameters of current controller and speed controller and the time response of both loops are investigated for varying input and step change in load torque.

2. MATERIALS AND METHODS

2.1. Reaction Curve Parameters

The open loop step response reaction (S-shape) curve $y(t)$ of a control system is shown on **Fig. 1**. This curve has an inflection point at time t_{inf} , where the first derivative reaches its maximum value and the second derivative is zero.

Traditional tuning method used measuring to determine the parameters of this response: L -the delay time and T -the time constant by plotting tangent at inflection point as shown on **Fig. 2**.

To determine the delay time and the time constant of response analytically we follow the following steps:

- Step1:** From the known time function $y(t)$, determine the first derivative $y'(t)$ and the second derivative $y''(t)$
- Step2:** Equating the second derivative to zero and solving this equation obtain t_{inf} , the time where the reaction curves exhibit inflection

Step3: Substituting the value of the inflection time into the expression of the first derivative, determine the maximum value $y'(t)_{max}$, which is the tangent of angle α

Step4: Using the triangular $(b1,b2,b3)$ on **Fig. 2**, determine $\tan \alpha$

$$\tan \alpha = \frac{y(t_{inf})}{t_{inf} - L} \text{ Or: } L = t_{inf} - \frac{y(t_{inf})}{\tan \alpha} \tag{1}$$

Step 5: Using the triangular $(b1,b4,b5)$ on **Fig. 2** find T :

$$\tan \alpha = \frac{y_{ss}}{T}, \text{ or } T = \frac{y_{ss}}{\tan \alpha} \tag{2}$$

where the steady state value of the output y_{ss} :

$$y_{ss} = \lim_{t \rightarrow \infty} y(t) \tag{3}$$

Step6: Use the calculated reaction curve parameters L and T and Ziegler-Nichols rules to tune the PI controller.




Fig. 1. Reaction curve $y(t)$ and its derivatives




Fig. 2. The parameters of reaction curve




Fig. 3. Closed loop armature current block diagram




Fig. 4. Closed loop speed control system block diagram

Equations (1-3) show how the output and its derivatives can be used to obtain reaction curve parameters.

2.2. Armature Current PI Controller Design

The current controller is designed for the extreme condition when back emf is zero, that is during starting period because at that time large current flows through the machine. The block diagram of the closed loop armature current is depicted on Fig. 3 where: R_a the armature resistance, L_a the armature inductance, K_r rectifier gain, T_r rectifier time constant, K_c PI controller gain and T_c PI controller time constant.

The plant transfer function is equation 4:

$$G_p(s) = \frac{I_a(s)}{V_c(s)} = \frac{K_r / R_a}{(T_a s + 1)(T_r s + 1)} \tag{4}$$

Assume a step change in V_c and taking inverse Laplace transform of both sides, we obtain the armature current and its derivatives:

$$i_a(t) = \frac{V_c K_r}{R_a} \left(1 - \frac{T_a}{T_a - T_r} e^{-t/T_a} - \frac{T_r}{T_r - T_a} e^{-t/T_r} \right) \tag{5}$$

$$i_a'(t) = \frac{V_c K_r}{R_a (T_a - T_r)} (e^{-t/T_a} - e^{-t/T_r}) \tag{6}$$

$$i_a''(t) = \frac{V_c K_r}{R_a (T_a - T_r)} \left(-\frac{1}{T_a} e^{-t/T_a} + \frac{1}{T_r} e^{-t/T_r} \right) \tag{7}$$

Equation (5) indicates that the armature current has two exponential terms and a constant term, that is mean

the output is of S-shape. The first derivative given by equation (6) has a maximum value and its derivative represented by equation (7) has an intersection point with real axis. These specifications will be used to determine reaction curve parameters.

Equating the second derivative given by equation (7) to zero and solving for inflection time results:

$$t_{inf} = \frac{T_a T_r}{T_a - T_r} \ln \frac{T_a}{T_r} \tag{8}$$

Without plotting the output of the loop $i(t)$, using equations (8) and (7) the angle of the tangent to the reaction curve can be calculated, then using equations (1) and (2) the parameters of the response are obtained and implemented in tuning the PI controller and for better response modified Ziegler-Nichols rules are used in this study.

2.3. Speed PI Controller Design

The block diagram of the closed loop speed control system is presented on Fig. 4 where K_b is the torque constant, B is the viscous friction coefficient, T_m is the mechanical time constant, K_n and T_n are the speed PI controller gain and time constant respectively, $G_c(s)$ is the armature current closed loop transfer function. T_n should be chosen such that it cancels the largest time constant in the transfer function in order to reduce the order of the system. Therefore the response will be much faster. The speed open loop transfer function is equation (9):

$$\frac{K_n b_0 s + b_1 K_n}{a_0 s^4 + a_1 s^3 + a_2 s^2 + a_3 s} \tag{9}$$

where the coefficients of the transfer function are:

$$b_0 = K_c K_r K_B T_c \tag{10}$$

$$b_1 = K_c K_r K_B \tag{11}$$

$$a_0 = T_c T_r T_m L_a \tag{12}$$

$$a_1 = T_c T_m (L_a + T_r) + T_c T_r L_a \tag{13}$$

$$a_2 = T_m (T_c R_a + K_r K_c L_a) + T_c (T_r + L_a) \tag{14}$$

$$a_3 = T_m K_r K_c R_a + T_c R_a + K_r K_c L_a \tag{15}$$

$$a_4 = K_r K_c R_{aa} \tag{16}$$

Equations (10-16) give the relationships between the system parameters and the coefficients of the transfer function of the same system and will be used in determining the critical gain and the critical period necessary to tune the speed PI controller.

The speed open loop system has a zero on the origin and the time response exhibits sustained oscillations when the proportional gain is at critical value K_{cr} , this critical value can be obtained theoretically from the Routh's stability criterion using the following speed closed loop transfer function:

$$\frac{\omega_{ref}(s)}{\omega(s)} = \frac{K_n b_0 s + b_1 K_n}{a_0 s^4 + a_1 s^3 + a_2 s^2 + (a_3 + K_n b_0) s + a_4 + b_1 K_n} \tag{17}$$

The characteristic equation (17) of the speed closed loop system is:

$$a_0 s^4 + a_1 s^3 + a_2 s^2 + (a_3 + K_n b_0) s + a_4 + b_1 K_n = 0 \tag{18}$$

From equation (18) arrange Routh's array as shown on **Table 1**, where:

$$A = \frac{(a_1 a_2 - a_0 a_3 - a_0 b_0 K_n)}{a_1 a_2 - a_0 (a_3 + K_n b_0)} \rightarrow (a_3 + K_n b_0) - a_1^2 b_1 K_n + a_4 \tag{19}$$

Examining the array of coefficients, the speed closed loop system becomes oscillatory when A equals zero, i.e:

$$(a_1 a_2 - a_0 a_3 - a_0 b_0 K_{cr})(a_3 + b_0 K_{cr}) - a_1^2 (b_1 K_{cr} + a_4) = 0 \tag{20}$$

Table 1. The array of coefficients

S^4	a_0	a_2	$a_4 + b_1 K_n$
S^3	a_1	$a_3 + K_n b_0$	0
S^2	$\frac{a_1 a_2 - a_0 (a_3 + K_n b_0)}{a_1}$	$a_4 + b_1 K_n$	
S^1	$\frac{SA}{S^0}$	0	0
S^0	$a_4 + b_1 K_n$		

Solving Equation 19, for critical gain results:

$$K_{cr} = -K_1 \pm \sqrt{(K_1^2 - K_2)} \tag{21}$$

Where:

$$K_1 = \frac{b_0 (2a_0 a_3 - a_1 a_2 + a_1^2 b_1)}{2a_0 b_0^2} \tag{22}$$

$$K_2 = \frac{a_3 (a_0 a_3 - a_1 a_2) + a_1^2 a_4}{2a_0 b_0^2} \tag{23}$$

The proportional gain of speed PI controller is determined using the calculated critical gain, equations (18-23) and the modified second Ziegler Nichols method for low overshoot of the output signal.

To find the frequency of the sustained oscillations a supplementary equation is performed using the coefficients of the third row in Routh's table as:

$$\frac{a_1 a_2 - a_0 (a_3 + K_{cr} b_0)}{a_1} s^2 + a_4 + b_1 K_{cr} = 0 \tag{24}$$

Replacing s by $j\omega$ and solving equation (24):

$$\omega_{cr} = \pm j \sqrt{\frac{a_1 (b_1 K_{cr} + a_4)}{(a_1 a_2 - a_0 a_3 - a_0 K_{cr} b_0)}} \tag{25}$$

The period of sustained oscillation is:

$$P_{cr} = 2\pi / \omega_{cr} \tag{26}$$

Equations (24-26) determined the critical period of the speed closed loop system, then the parameters of the PI speed controller can be adjusted from the calculated critical gain and critical period.

2.4. Cascade System Simulation

A double loop cascade control system is simulated using the following components.

1: 5 HP, 240V separately excited DC motor with parameters as:

Moment of Inertia, $J = 0.05 \text{ Kg.m}^2$.




Fig. 5. MATLAB/Simulink model of cascade system

Back EMF Constant $K_e = 2$ Volt.sec/rad.
 Rated Current = 16 A.
 Resistance of Armature, $R_a = 0.5$ ohm.
 Armature Inductance, $L_a = 0.01$ H.
 Viscous friction coefficient, $B = 0.02$ Nm/rad/s
 Mechanical time constant $T_m = J/B$ s
 Torque constant $K_B = K_e/B$

2: Single phase rectifier:

Rectifier gain, $K_r = 24$
 Rectifier time constant, $T_r = 0.005$ s
 Input control signal, $V_c = 10$ V

3: PI current controller:

Proportional gain, $K_c = 3.45$
 Integral time constant, $T_c = 0.0128$ s

4: PI speed controller:

Proportional gain, $K_n = 0.96$
 Integral time constant, $T_n = 0.05$ s

The components of the cascade system connected together are shown on Fig. 5 where the current loop contains the armature circuit (electrical part), the rectifier and PI current controller and the speed loop contains the closed loop current loop, mechanical part and PI speed controller.

3. RESULTS

In order to validate the control strategies were developed, simulations are carried out. These simulations are made for current control loop and for speed control loop.

3.1. Armature Current Closed Loop Response

The dynamic performances of the closed loop armature current are obtained using MATLAB/Simulink model of cascade system shown on Fig. 5 when the PI speed controller is disconnected and the reference signal is applied directly to the PI current controller.




Fig. 6. Current loop start up time response




Fig. 7. Current loop time response to step change on load torque

The startup time response of the closed loop armature current is shown on Fig. 6. The figure shows two curves, one curve for no load start up and the other when the motor starts with half rated load on the shaft, the plot indicates that both curves are approximately identical, which means the current closed loop rejects the disturbances caused by the mechanical load. From other hand the maximum overshoot is nearly 30%. This value of overshoot is acceptable, because the rated starting current of DC motors is twice the name plate current. The time response is 10 time faster than the response of uncontrolled system.

The time response of the closed loop armature current to a 50% step change on load torque is plotted on **Fig. 7**. The step change in load torque is applied at $t = 0.2$ sec before this time the motor was running on steady state operating point. The oscillations of armature current is smaller than the oscillations cause by the reference signal.

3.2. Angular Speed Closed Loop Response

The start up time response of the speed closed loop system is shown on **Fig. 8** with no load and with rated load. These two curves indicate that disturbance in cascade system has no effect on the dynamic performances.

On **Fig. 9** the time response of the speed loop for step change on motor load applied at $t = 0.5$ sec is plotted. The speed of cascade system oscillates in the region of its steady state value and then go back to the speed

determine by reference signal, this means that the steady state error of this closed loop is zero.




Fig. 8. Speed loop start up time response




Fig. 9. Speed loop time response to step change on load torque




Fig. 10. Tuning the time response of speed loop




Fig. 11. Time response of the hall system

To achieve preferred overshoot for the speed loop, Crnosija *et al.* (2005) inserted a filter with unity gain and different value of time constant on the system input. If the time constant of the input filter is 0.02 sec, the percent maximum overshoot is reduced from 70 to 10% as exposed on Fig. 10.

The maximum overshoot can be reduced by tuning the parameters of PI speed controller especially the integration time constant T_n , but the speed of the system response is lower. Finally, the time response of the drive system is presented on Fig. 11. When the reference signal is reduced by 50% at $t = 0.8$ sec and the load torque is increased to its nominal value at $t = 1.6$ sec.

4. DISCUSSION

This study covers an analytical method for design of double loop cascade system contains a separately excite DC motor and full controlled single phase rectifier. For inner loop (armature current loop), using the armature current time function and its derivatives a mathematical expressions are derived for reaction curve parameters, they are the delay time (l) and the Time constant (T), these two parameters are used to calculate the gain and time constant of a proportional plus integral controller, the calculated parameters are implemented in simulations investigation the time response performances of this loop.

For the outer loop (speed loop), critical gain and the critical period of the oscillated response are determined using developed relationships and implemented to determine the speed PI controller parameters. The

dynamic behavior of the speed closed loop is analyzed using Simulink software. Different tuning rules for both controllers were examined during simulations.

The time response of the armature current closed loop is fast, has zero steady state error and acceptable overshoot for DC motors. The time response of the speed closed loop has one disadvantage which that a high percent overshoot but its corrected using a filter in the input of the system

5. CONCLUSION

In the present study, a mathematical expression for armature current PI controller and for speed of rotation PI controller are derived and used in calculations of the gain and of the time constant for both controllers. The cascade system is simulated and the time response is plotted and investigated. For current loop it is better to adjust the parameters of PI controller applying modified Ziegler-Nichols first method to reduce the overshoot of the armature current, while for speed PI controller it is reasonable to implement modified second Ziegler-Nichols method for small overshoot and tune the integrator time constant, or better introduce a filter into the input of the system.

The proposed method for determination of the parameters of the controllers can be used in all DC drive systems and in AC drive systems, also in process control system with a single closed loop where PI controller is replaced by PID controller.

6. REFERENCES

- Crnosija, P., R. Krishnan and T. Bjazic, 2005. Transient performance based design optimization of PM brushless DC motor drive speed controller. Proceedings of the IEEE International Symposium on Industrial Electronics, Jun. 20-23, IEEE Xplore Press, pp: 881-886. DOI: 10.1109/ISIE.2005.1529040
- Lee, C.H., 2004. A survey of PID controller design based on gain and phase margin. Int. J. Comput. Cognit., 2: 63-100.
- Moleykutty, G., 2008. Speed control of separately excited DC motor. Am. J. Applied Sci., 5: 227-233. DOI: 10.3844/ajassp.2008.227.233
- Neenu, T. and P. Poongodi, 2009. Position control of DC motor using genetic algorithm based PID controller. Proceedings of the World Congress on Engineering, Jul. 1-3, London, UK., pp: 1618-1622.
- Sing, R. and A.K. Pandey, 2012. Stability analysis of closed loop control of SEDC motor using routh-hurwitz criteria. GJCAT, 2: 926-928.