

The Thermo-Economics Analysis of the Optimum Thickness of Double-Layer Insulation for Air Conditioning Duct

¹N. Sophonpongpipat, ¹P. Jaruyanon and ²S. Nanetoe

¹Department of Mechanical Engineering,

²Department of Industrial Engineering and Management,

Faculty of Engineering and Industrial Technology, Silpakorn University, Thailand 73000

Abstract: Problem statement: Engineering economics played an important role in engineering design works. The net saving value was the easiest criterion to indicate the optimum design. However, the information about the net saving analysis of double-layer insulation of air conditioning duct was insufficient. Thus, it was important to study this case. **Approach:** The optimum thickness analysis of air conditioning duct's insulation, which composes of the layer of rubber and fiber glass insulator, was conducted by means of thermo-economics method. In addition, the effects of heat transfer coefficient at inside and outside of duct on the optimum thickness of these insulators were also studied. The research was done by considering the insulation's optimum thickness of circular galvanized steel duct. The duct diameter of 0.5 m with rubber insulator ($k = 0.035 \text{ W m}^{-1} \text{ K}^{-1}$) and fiber glass insulator ($k = 0.045 \text{ W m}^{-1} \text{ K}^{-1}$) was selected to show the study results. In order to study the change in optimum thickness when convective heat transfer coefficients were varied, the inside and outside duct convective heat transfer coefficient of 6, 10, 14, 18 and 22 $\text{W m}^{-2} \text{ K}^{-1}$ were selected for calculation of optimum thickness. **Results:** The results showed that the variation of inside and outside duct's heat transfer coefficient did not affect on the insulator's optimum thickness. In the case of a circular duct of 0.5 m in diameter and the inside and outside convective heat transfer coefficient of 6 and 22 $\text{W m}^{-2} \text{ K}^{-1}$ respectively, the optimum thickness was 0.0032 and 0.125 m for rubber and fiber glass insulator respectively. The net saving was 34,173.00 Baht per meter of duct. **Conclusion:** Finally, when the consideration in terms of insulator cost was done, the thermo-economics analysis of optimum thickness of double-layer insulation was recommended when the cost of main insulator was higher than that of auxiliary insulator otherwise the thermo-economics analysis of optimum thickness of single-layer insulation was sufficient. In addition, the variation of inside and outside duct convective heat transfer coefficient did not affect the optimum thickness. But net saving increased when inside and outside duct convective heat transfer coefficient increased.

Key words: Thermo-economics, optimum thickness, duct insulation, net saving

INTRODUCTION

In a present day, the economical design is an important issue in thermal engineering work. The optimum design, minimum cost and high efficiency, is the necessary requirement. In order to fulfill this requirement, there are many works tried to find out the criteria for the optimum design (Umberto *et al.*, 2009; Nelson *et al.*, 2009; David *et al.*, 2009; Soylemez, 2001a; 2001b). In case of thermal insulation, many works deal with the optimum thickness of insulation, both in building wall (Jinghua *et al.*, 2009; Ozel and Pihitli, 2007; Bolatturk, 2006) and refrigeration application

(Soylemez and Unsal, 1999). Although there are many concepts for finding the optimum point, the simplest concept was introduced by Soylemez and Unsal (1999). They showed that the net saving value was the easiest criterion to indicate the optimum point. In addition, they showed the calculation method of optimum insulation thickness for single-layer insulation in refrigeration applications. However, we can see that there is a difference in cost of various types of insulator. In some case, a mixed insulation, the use of more than one type of insulator, may be more suitable. For example, the cost of rubber insulator is higher than that of the fiber glass insulator but we select the rubber

Corresponding Author: N. Sophonpongpipat, Department of Mechanical Engineering, Faculty of Engineering and Industrial Technology, Silpakorn University, Thailand 73000 Tel: +66-34-259025 Fax: +66-34-219367

insulator in refrigeration and air conditioning application to avoid wetting inside insulator due to condensation of air's moisture at the cold surface. In this case, if the thickness of rubber insulator is enough to prevent condensation, we can use the fiber glass insulator as adjacent insulator layer to reduce heat flow into the duct instead of the use of only rubber insulator. According to above example, we called, in this study, the rubber insulator as main insulator and the fiber glass insulator as auxiliary insulator. Unfortunately, the information about the optimum point of insulation system that consists of various layers of insulator materials is insufficient. Thus, this study will consider the optimum thickness of air conditioning's duct insulation which consists of the layer of rubber and fiber glass insulator by using maximum net saving criterion. Moreover, the variation of optimum thickness, when the convective heat transfer coefficients at inside and outside of duct were changed, was also investigated.

MATERIALS AND METHODS

Mathematical model:

Thermal calculation: Figure 1 shows the cross section area and thermal resistances of the bare air conditioning duct. The amount of radius heat flow into the duct ($Q_{\text{bare duct}}$) can be calculated by the following Eq. 1:

$$Q_{\text{bare duct}} = \frac{\Delta T}{Z_{\text{total, bare duct}}} \quad (1)$$

Temperature difference between the outside and inside of duct (ΔT) can be found by:

$$\Delta T = T_{o,\text{mean}} - T_{i,\text{mean}} \quad (2)$$

Total thermal resistances ($Z_{\text{total, bare duct}}$), in case of bare duct, can be determined by summation of inner duct thermal resistance due to heat convection (Z_1), thermal resistance due to heat conduction in duct material (Z_2) and thermal resistance due to outer heat convection (Z_3):

$$Z_{\text{total, bare duct}} = \frac{1}{h_i A_i} + \frac{\ln\left(\frac{R_{o,\text{duct}}}{R_{i,\text{duct}}}\right)}{2\pi L_{\text{duct}} k_{\text{duct}}} + \frac{1}{h_o A_o} \quad (3)$$

Where:

$$A_i = 2\pi R_{i,\text{duct}} L_{\text{duct}} \quad (4)$$




Fig. 1: The cross section area and thermal resistances of the bare air conditioning duct




Fig. 2: The thermal resistance in case of an insulated duct with rubber insulator as inner insulator layer and fiber glass insulator as outer insulator layer

$$A_o = 2\pi R_{o,\text{duct}} L_{\text{duct}} \quad (5)$$

In case of insulated duct with rubber insulator as inner insulator layer and fiber glass insulator as outer insulator layer, the thermal resistance was shown in Fig. 2. The radius heat flow in this case ($Q_{\text{ins duct}}$) can be determined by the following Eq. 6:

$$Q_{\text{ins duct}} = \frac{\Delta T}{Z_{\text{total, Ins duct}}} \quad (6)$$

Total thermal resistances ($Z_{\text{total, Ins duct}}$), in case of insulated duct, can be determined by summation of Z_1 , thermal resistance of inner insulator layer ($Z_{\text{ins,1}}$), thermal resistance of outer insulator layer ($Z_{\text{ins,2}}$) and Z_3 :

$$Z_{\text{total,ins duct}} = \frac{1}{h_i A_i} + \frac{\ln\left(\frac{R_{o,duct}}{R_{i,duct}}\right)}{2\pi L_{duct} k_{duct}} + \frac{\ln\left(\frac{R_{ins,1}}{R_{o,duct}}\right)}{2\pi L_{duct} k_{ins,1}} + \frac{\ln\left(\frac{R_{ins,2}}{R_{ins,1}}\right)}{2\pi L_{duct} k_{ins,2}} + \frac{1}{h_o A_o} \quad (7)$$

The amount of heat flow, which can be decreased by insulation, can be found by following Eq. 8:

$$Q_{\text{save}} = Q_{\text{bare duct}} - Q_{\text{ins duct}} \quad (8)$$

Net saving calculation: The net Saving (S) is a function of the difference between the cost of saving energy and the cost of materials, installation, operation and resale value, by:

$$S = \frac{P_1 C_E Q_{\text{save}} \Delta t}{\text{COP}} - P_2 [(C_{ins,1} A_{ins,1} x_{ins,1} + C_{ins,2} A_{ins,2} x_{ins,2}) + C_{install,1} A_{ins,1} + C_{install,2} A_{ins,2}] \quad (9)$$

Where:

- C_E = Energy cost (Baht kWh⁻¹)
- Δt = Operation time of air conditioning system (h)
- COP = Coefficient of Performance
- $C_{ins,1}$ and $C_{ins,2}$ = Materials cost of inner and outer insulator (Baht m⁻³)
- $A_{ins,1}$ and $A_{ins,2}$ = Area of inner and outer insulator (m²)
- $x_{ins,1}$ and $x_{ins,2}$ = Thickness of inner and outer insulator (m)
- $C_{install,1}$ and $C_{install,2}$ = Installation cost of inner and outer insulator (Baht m⁻²)
- P_1 and P_2 = Calculated by:

$$P_1 = \frac{N}{1+i} \text{ if } i = d \quad (10)$$

$$P_1 = \frac{1}{(d-i)} \left[1 - \left(\frac{1+i}{1+d} \right)^N \right] \text{ if } i \neq d \quad (11)$$

$$P_2 = 1 + P_1 M_s - R_v (1+d)^{-N} \quad (12)$$

Where:

- i and d = Interest and inflation rate
- N = Life cycle period of insulator
- M_s = Ratio of maintenance and operation cost to initial cost
- R_v = Ratio of resale value to initial cost

The positive sign of net saving implies that the insulation of duct gives benefits. In contrast, the negative sign means that the insulation of duct is worthless. In fact, the best design occurs when the net saving is highest. The insulation thickness that corresponds to the highest net saving is called the optimum thickness. Calculation of Eq. 9 cooperated with graphical method is the most suitable method to find the optimum thickness. The detail will discuss as follows.

RESULTS

Case study: In order to verify the assumption that the net saving of double-layer of insulation is higher than that of the single-layer insulation, the case study will be selected. The information of case study is shown in Table 1.

Table 1: The information of case study

Item	Description	Value
1	Duct diameter	0.5 m
2	Thermal conductivity of duct	60.5 W m ⁻¹ K ⁻¹
3	Thermal conductivity of rubber insulator	0.035 W m ⁻¹ K ⁻¹
4	Thermal conductivity of fiber glass insulator	0.045 W m ⁻¹ K ⁻¹
5	Inside duct convective heat transfer coefficient	6 W m ⁻² K ⁻¹
6	Outside duct convective heat transfer coefficient	22 W m ⁻² K ⁻¹
7	Temperature difference between inside and outside of duct	13°C
8	Interest rate	14.25%
9	Inflation rate	2.1%
10	Life cycle period of insulator	10 years
11	Ratio of maintenance and operation cost to initial cost	0
12	Ratio of resale value to initial cost.	0
13	Energy cost	2.978 Baht kWh ⁻¹
14	Rubber insulator cost	40697 Baht m ⁻³
15	Fiber glass insulator cost	5927.20 Baht m ⁻³
16	Installation cost of rubber insulator	270 Baht m ⁻²
17	Installation cost of fiber glass insulator	110 Baht m ⁻²
18	Operation hours of air conditioning system	23,040 h years ⁻¹
19	Average COP	2.81

Figure 3 shows the calculation results of net saving of above information. The vertical axis shows net saving in Baht m^{-1} of duct after 23,040 h of operation. The primary horizontal axis displays the rubber insulator thickness in meters and the secondary horizontal axis shows the fiber glass insulator thickness in meters. We can see that if we use only rubber insulator for duct insulation, the optimum thickness of rubber insulator is 0.05 m and the net saving of this thickness is 30,201 Baht m^{-1} of duct. In the other hand, if we use rubber and fiber glass insulator for duct insulation, the optimum thickness of rubber and fiber glass insulator is 0.0032 and 0.125 m, respectively. The net saving is 34,173 Baht m^{-1} of duct.

The effect of inside duct convective heat transfer coefficient on optimum thickness: Figure 4 shows the effect of inside duct convective heat transfer coefficient on optimum thickness. Figure 4 indicated that, although the inside duct convective heat transfer coefficient was varied from 6-22 $W m^{-2} K^{-1}$, the optimum thickness of fiber glass and rubber insulator was constant at 0.125 and 0.0032 m respectively.




Fig. 3: The calculation results of net saving of the case study




Fig. 4: The effect of inside duct convective heat transfer coefficient on optimum thickness

It should be noted from Fig. 5 that when inside duct convective heat transfer coefficient is increased from 6-22 $W m^{-2} K^{-1}$, the net saving increases from 34,172-87,748 Baht m^{-1} of duct.

The effect of outside duct convective heat transfer coefficient on optimum thickness: Figure 6 shows the effect of outside duct convective heat transfer coefficient on optimum thickness. Figure 6 indicated that, although the outside duct convective heat transfer coefficient was varied from 6-22 $W m^{-2} K^{-1}$, the optimum thickness of fiber glass and rubber insulator was constant at 0.125 and 0.0032 m respectively. Figure 7 shows that when outside duct convective heat transfer coefficient is increased from 6-22 $W m^{-2} K^{-1}$, the net saving increases from 19,675-34,172 Baht m^{-1} of duct.




Fig. 5: The relationship between net saving and inside duct convective heat transfer coefficient




Fig. 6: The effect of outside duct convective heat transfer coefficient on optimum thickness




Fig. 7: The relationship between net saving and outside duct convective heat transfer coefficient

DISCUSSION

Case study: The result from Fig. 3 shows that the net saving of double-layer insulation is higher than that of only rubber insulation. In contrast, the net saving of double-layer insulation is lower than that of only fiber glass insulation. Thus, if the fiber glass insulator is suitable for a given application without the technical problems, the determination of optimum thickness by thermo-economics analysis of single layer is sufficient. This is because the materials cost of fiber glass is extremely lower than that of rubber insulator. From above discussion, it can be concluded that when we consider in term of materials costs, the thermo-economics analysis of optimum thickness of double-layer insulation is recommend when the cost of main insulator is higher than that of auxiliary insulator otherwise the thermo-economics analysis of optimum thickness of single-layer insulation is sufficient.

The effect of inside duct convective heat transfer coefficient on optimum thickness: We can clearly see from the Fig. 4 that the variation of inside duct convective heat transfer coefficient does not affect on optimum thickness. This means that the designer have not to concentrate on the uncertainty of convective heat transfer coefficient in real application. However, Fig. 5 shows that when inside duct convective heat transfer coefficient is increased, the net saving increases. This means that if the pay back period is a serious design criterion, the precision value of convective heat transfer coefficient is needed. Thus it can be concluded that the variation of inside duct convective heat transfer coefficient does not affect optimum thickness.

The effect of outside duct convective heat transfer coefficient on optimum thickness: We can clearly see from Fig. 6 that the variation of outside duct convective heat transfer coefficient does not affect optimum thickness. Figure 7 shows that when outside duct convective heat transfer coefficient is increased, the net saving increases. As same as discuss in above topic, when the pay back period is a serious design criterion, the precision value of convective heat transfer coefficient is needed. Thus it can be concluded that the variation of outside duct convective heat transfer coefficient does not affect optimum thickness.

CONCLUSION

When the consideration in terms of insulator cost was done, the thermo-economics analysis of optimum thickness of double-layer insulation is recommended when the cost of main insulator is higher than that of auxiliary insulator otherwise the thermo-economics analysis of optimum thickness of single-layer insulation is sufficient.

The variation of inside and outside duct convective heat transfer coefficient does not affect optimum thickness. But net saving increases when inside and outside duct convective heat transfer coefficient increases.

ACKNOWLEDGEMENT

The authors would like to thank Department of Mechanical Engineering, Faculty of Engineering and Industrial Technology, Silpakorn University for all support to this study.

REFERENCES

- Bolatturk, A., 2006. Determination of optimum insulation thickness for building walls with respect to various fuels and climate zones in Turkey. *Applied Therm. Eng.*, 26: 1301-1309. DOI: 10.1016/j.applthermaleng.2005.10.019
- David, B., M. Gassner, T. Fuchino and F. Marechal, 2009. Thermo-economic analysis for the optimal conceptual design of biomass gasification energy conversion systems. *Applied Therm. Eng.*, 29: 2137-2152. DOI: 10.1016/j.applthermaleng.2007.06.021
- Jinghua, Y., C. Yang, L. Tian and D. Liao, 2009. A study on optimum insulation thicknesses of external walls in hot summer and cold winter zone of China. *Applied Energy*, 86: 2520-2529. DOI: 10.1016/j.apenergy.2009.03.010

- Umberto, D., S. Proietti and P. Sdringola, 2009. Solar-powered cooling systems: Technical and economic analysis on industrial refrigeration and air-conditioning applications. *Applied Energy*, 86: 1376-1386. DOI: 10.1016/j.apenergy.2009.01.011
- Nelson, F., P.J. Mago and L.M. Chamra, 2009. Energy and economic evaluation of cooling, heating and power systems based on primary energy. *Applied Thermal Eng.*, 29: 2665-2671. DOI: 10.1016/j.applthermaleng.2008.12.027
- Ozel, M. and K. Pihitili, 2007. Optimum location and distribution of insulation layers on building walls with various orientations. *Build. Environ.*, 42: 3051-3059. DOI: 10.1016/j.buildenv.2006.07.025
- Soylemez, M.S. and M. Unsal, 1999. Optimum insulation thickness for refrigeration applications. *Energy Convers. Manage.*, 40: 13-21. DOI: 10.1016/S0196-8904(98)00125-3
- Soylemez, M.S., 2001a. On the optimum sizing of cooling towers. *Energy Convers. Manage.*, 42: 783-789. DOI: 10.1016/S0196-8904(00)00148-5
- Soylemez, M.S., 2001b. On the optimum channel sizing for HVAC systems. *Energy Convers. Manage.*, 42: 791-798. DOI: 10.1016/S0196-8904(00)00149-7